

Schena, Cristeen

From: Kevin Stetson <kstetson@woodardcurran.com>
Sent: Wednesday, August 19, 2015 10:30 AM
To: david.burns@state.ma.us; Turin, David; ryan.joyce@state.ma.us; jsullivan@town.hull.ma.us
Cc: Aram Varjabedian; Frank Cavaleri; jdow@town.hull.ma.us
Subject: Follow up for Hull, Ma WPCF MA0101231 SSO reported on 8-17-15
Attachments: SSO 8-17-15 sludge truck overflow.pdf; Hull WPCF sludge truck filling SOP updated 8-19-15.docx

As a response to the SSO on 8/17/15 we have revised our truck loading SOP to clarify the truck driver's responsibilities during the filling of the tanker to avoid any future overfilling of the truck. The original SSO report and our revised SOP is attached. The changes to the SOP are highlighted on Page 3, step #8.

Kevin Stetson
Assistant Plant Manager
Hull WWTF
1111 Nantasket Ave.
Hull, MA, 02045
781-925-0906